

VOC Content Test Certificate

Wednesday, 28th December 2022

Supplier: Look Floors (9 Industry Road, Penrose, Auckland, 1061, New Zealand).

Sample Description: STRONGBOND 980 HT Vinyl Plank & Tile Adhesive

Date Tested: December 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC)
Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as
South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	STRONGBOND 980 HT Vinyl Plank & Tile Adhesive
General Purpose Adhesives and sealants Limit: 50 grams per litre	1 gram per litre as VOC content per material
<i>We here by certify that STRONGBOND 980 HT Vinyl Plank & Tile Adhesive is below the VOC content limits of the chosen categories specified by Green Star Design & As Built, Green Building Council of Australia.</i>	



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
B Sc (Biotechnology)
Senior Consultant

Issue date: 28/12/2022

Expiry date: 28/12/2027

P22120048